

EasiClamp[®] Gas Repair Clamp

CT Series

APPLICATION

A mechanical 2-part split clamp for the repair of damaged or leaking iron gas pipes for underground installations only.

DESCRIPTION

Comprising coated, ductile iron housings with special rubber waffle gaskets to produce an easy to install high strength Repair Clamp. The Clamp has a wide diameter tolerance and can accommodate angular misalignment up to 4°.

CONSTRUCTION

- Housing: SG Iron
- Waffle Gasket: NBR rubber
- Fasteners: Steel, Sheraplex coated
- Corrosion protection: Rilsan Nylon coating

INSTALLATION

The EasiClamp can be assembled using conventional hand tools and should be installed following the instructions for pipe preparation, cleaning and the tightening of fasteners included with the product. M16 Fasteners – Torque to 95 Nm.

SPECIFICATION

Maximum Operating Pressure (MOP) = 2.0 Bar. Complies with gas industry specification GIS/LC8-4:2006.



Every effort has been made to ensure that the information contained in this publication is accurate at the time of publishing. Crane Ltd assumes no responsibility or liability for typographical errors or omissions or for any misinterpretation of the information within the publication & reserves the right to change without notice.



TECHNICAL HELPLINE: +44 (0) 1462 443226 e: sales@wask-uk.com w: www.wask-uk.com

DATASHEET

EASICLAMP[®] GAS REPAIR CLAMP


PIPE SIZES


Available in sizes from 80mm (3") to 150mm (6").

DIMENSIONS

All dimensions in mm.

SIZE = NOMINAL DIAMETER						
PART NO.	SIZE	DIA RANGE		~	Y	z
		MIN	MAX	X		2
CT2800	DN80 (3")	85.4	103.0	184	145	200
CT2801	DN100 (4")	111.8	129.4	211	167	200
CT2802	DN 150 (6")	165.2	184.8	267	217	200







To visit our Video Library go to: www.youtube.com/user/CraneBSU



46-48 WILBURY WAY, HITCHIN, HERTFORDSHIRE, SG4 0UD

TELEPHONE: +44 (0)1462 443225 TELEPHONE: +44 (0)1462 443226 FAX: +44 (0)1462 443311 EMAIL: sales@wask-uk.com

www.wask-uk.com



11 EMS 55377

• Designed and manufactured under quality management systems in accordance with BS EN ISO 9001.

Every effort has been made to ensure that the information contained in this publication is accurate at the time of publishing. Crane Ltd assumes no responsibility or liability for typographical errors or omissions or for any misinterpretation of the information within the publication and reserves the right to change without notice. W_EGRC_0221_v1